

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:39 pm

PWS ID: UTAH22061 **Name:** ASPEN ACRES ASSOCIATION
Legal Contact: ASPEN ACRES ASSOCIATION **Rating:** Approved
RICK ALLIS **Rating Date:** 11/22/2010
Address: ASPEN ACRES ASSOCIATION **Activity Status:** Active
OAKLEY, UT 84055
Phone Number: 435-783-7824
City Served (Area):
County: SUMMIT COUNTY
System Type: Non-community **Last Inv Update:** 05/03/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 09/10/2010 **Total Dsgn Cap:**
Population: 200 **Surveyor:** HAROLD ZANE DEWEI **Total Emerg Cap:**
Oper Period: 6/1 to 9/30

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	ALLIS, RICK				

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	100
			100 Total Svc Connections

Storage

Total Storage: 35,000 GAL **Number of Units:** 3 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST003	50,000 GALLON CONCRETE TANK	UK				P	
ST001	STORAGE FACILITY ST001	Ground	15,000 GAL	Fiberglass		A	NO
ST002	STORAGE FACILITY ST002	Ground	20,000 GAL	Fiberglass		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	ASPEN ACRES CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	ASPEN ACRES SPRING	Active	SP				Yes	GW	Seasonal	6/1 to 9/30	
WS002	ASPEN WELL	Inactive	WL				No	GW	Other		

*Reports measured flow for wells, approved design capacity for all other sources.